

Government of Jammu & Kashmir
Department of Rural Development & Panchayati Raj
OFFICE OF THE BLOCK DEVELOPMENT OFFICER SANGRAMA

No: - BDO/SB/Pyt/2119
Dated: 18/08/2022

To Whom It May Concern

SANITATION CERTIFICATE

As reported by the Secretary Panchayat Halqa Sangrama of this Block, the School/Institution namely **G. D. Goenka Public School Baramulla situated at Sangrama** has neat and clean surroundings and possess adequate sanitation facilities as on date.

Hence, Sanitation Certificate is issued in favour of the above mentioned School/Institution.


Block Development Officer
Block Development Officer
Block Development Officer
Block Sangrama.

KASHMIR PUBLIC HEALTH ENGINEER DEPARTMENT

PHYSICO - CHEMICAL WATER ANALYSIS REPORT

SAMPLE ANALYSED AT: - DIST/DIVISION LAB PHE DIVISION BARAMULLA.

Sample Description. -


Source. - Tube-wellScheme. - WSS 1.4MGD Aug.BlaVillage/Panchayat/Block- Sangrama BaramullaPlace of Collection. - At Source point:Date of Collection. - 24/01/2024.Status. - Draw
~~Created~~ water.Date of Receipt. - 24/01/2024Forwarded/Collected By. - Mohd Ashraf Khan
(Assistant Officer)Date of Examination. - 24/01/2024 To
27/01/2024.Report Issued to: G. D. GOENKA PUBLIC SCHOOL SANGRAMA BARAMULLA.R E P O R T

S.No	Parameters	Units	Results	Permissible Limits	Max. Tolerance Limits
1	Total Alkalinity	mg/l	50	200	600
2	Chlorides(as Cl-)	mg/l	60	250	1000
3	Calcium	mg/l	40	75	200
4	Coli form	MPN	Absent	Not detected	Not detected
5	Fluorides(as F-)	mg/l	0.2	1	1.5
6	Total Hardness(as CaCo3)	mg/l	180	200	600
7	Total Iron	mg/l	0.00	0.3	1
8	Magnesium(as Mg)	mg/l	155.7	100	300
9	Nitrate	mg/l	0.00	45	45
10	pH at °C	-	7.40	6.5-8.5	8.5
11	Residual Chlorine	mg/l	0.00	0.2	1
12	Total Dissolved Solids	mg/l	311.1	500	2000
13	Turbidity	NTU	5.40	1	5
14	Taste & odour	-	Agreeable	Agreeable	Agreeable -
15	Phosphate	mg/l	0.1	1	5
16	Conductivity	µs/cm	625.4	1000	2000

IMPRESSION:-

All The above Essential quality Tested Parameters are within permissible limits. Water is safe for drinking.


 Lab Assistant/s


 Chemist
Distt. Water Testing Laboratory
P.H.E. Division Baramulla